

INFORMATION SHEET FOR AIR CONDITIONERS, EXCEPT DOUBLE DUCTS AND SINGLE DUCTS(5)

As by Comission Communication in the framework of ecodesign requirements for air conditioners and comfort fans (EU Regulation no. 206/2012) and of energy labelling of air conditioners - (EU Regulation no. 626/2011)

Function to which information ap	plies			If information applies to heating: I	neating season to v	vhich information	on relates.	
Cooling				5				
Heating				Heating (Average)(-10°C)			Y	
		,	<u> </u>	Heating (Warmer)(+2°C)		Y		
				Heating (Colder)(-22°C)			N	
Item	symbol	value	unit	Item	symbol	value	unit	
Design load				Seasonal efficiency				
Cooling	Pdesignc	2.6	kW	Cooling	SEER	6.1		
Heating (Average)(-10°C)	Pdesignh	2.1	kW	Heating (Average)(-10°C)	SCOP (A)	4.0	_	
Heating (Warmer)(+2°C)	Pdesignh	2.3	kW	Heating (Warmer)(+2°C)	SCOP (W)	5.1	-	
leating (Colder)(-22°C)	Pdesignh	-	kW	Heating (Colder)(-22°C)	SCOP (C)	-	-	
Declared capacity (*) for cooling, butdoor temperature Tj	at indoor temper	rature 27(19)°C	and	Declared Energy efficiency ratio (*outdoor temperature Tj) for cooling, at inc	door temperatu	re 27(19)°C and	
Гj = 35°С	Pdc	2.61	kW	Tj = 35°C	EERd	3.00	-	
rj = 30°C	Pdc	1.76	kW	Tj = 30°C	EERd	4.97	-	
Гj = 25°С	Pdc	1.23	kW	Tj = 25°C	EERd	7.53	-	
⁻j = 20°C	Pdc	1.16	kW	Tj = 20°C	EERd	10.22	-	
Declared capacity (*) for heating / 20°C and outdoor temperature Tj				Declared Coefficient of Performan temperature 20°C and outdoor ten	perature Tj	<u> </u>		
Γj = -7°C	Pdh	2.03	kW	Tj = -7°C	COPd	2,47	-	
Гj = 2°С Гi = 7°С	Pdh	1.10	kW	Tj = 2°C	COPd	4.33	-	
j = 7°C Tj = 12°C	Pdh Pdh	0.78 0.75	kW kW	Tj = 7°C Tj = 12°C	COPd COPd	4.89 5.82	-	
Γj = 12·C Γj = bivalent temperature	Pdh	2.03	kW	Tj = bivalent temperature	COPd	2.47		
Fi = operating limit temperature	Pdh	2.29	kW	Tj = operating limit temperature	COPd	2.22	-	
Declared capacity (*) for heating /			nperature	Declared Coefficient of Performantemperature 20°C and outdoor ten	ce (*) for heating /	•	n, at indoor	
Γį = 2°C	Pdh	2.33	kW	Ti = 2°C	COPd	2.79	_	
Γj = 7°C	Pdh	1,54	kW	Tj = 7°C	COPd	5.50	-	
rj = 12°C	Pdh	0.98	kW	Tj = 12°C	COPd	6.10	=	
Fi biralant to contact	-	2.22						
	Pdh	2.33	kW	Tj = bivalent temperature	COPd	2.79	-	
,	Pdh Pdh	2.33	kW kW	Tj = bivalent temperature Tj = operating limit temperature	COPd COPd	2.79 2.79	-	
rj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj	Pdh / Colder season,	2.33	kW perature 20	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten	ce (*) for heating /	2.79	-	
Fj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fj = -7°C	Pdh	2.33	kW	Tj = operating limit temperature Declared Coefficient of Performan	ce (*) for heating /	2.79 Colder season,	at indoor	
Fj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fj = -7°C Fj = 2°C	Pdh / Colder season, Pdh	at indoor temp	kW perature 20 kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C	ce (*) for heating / perature Tj	2.79 Colder season,	at indoor	
Fj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fj = -7°C Fj = 2°C Fj = 7°C	Pdh / Colder season, Pdh Pdh	at indoor temp	kW perature 20 kW kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C	ce (*) for heating / nperature Tj COPd COPd	2.79 Colder season,	at indoor	
C and outdoor temperature Tj = -7°C Tj = 7°C Tj = 7°C Tj = 7°C Tj = 12°C	Pdh / Colder season, Pdh Pdh Pdh Pdh	at indoor temp	kW cerature 20 kW kW kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C	ce (*) for heating / herature Tj COPd COPd COPd COPd	2.79 Colder season,	at indoor	
Fig. = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fig. = -7°C Fig. = 7°C Fig. = 12°C Fig. = 12°C Fig. = bivalent temperature	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh	at indoor temp	kW perature 20 kW kW kW kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C	ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd	2.79 Colder season,	at indoor	
Fj = operating limit temperature Declared capacity (*) for heating //C and outdoor temperature Tj Fj = -7°C Fj = 2°C Fj = 7°C Fj = 12°C Fj = bivalent temperature Fj = operating limit temperature	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh	at indoor temp	kW coerature 20 kW kW kW kW kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COPd	2.79 Colder season,	at indoor	
Tj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	at indoor temp	kW coerature 20 kW kW kW kW kW kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	at indoor	
Tj = operating limit temperature Declared capacity (*) for heating // C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Bivalent temperature Heating (Average)	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv	2.33 at indoor temp	kW kW kW kW kW kW kW kW kW contained the containe	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	at indoor	
Fj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fj = 7°C Fj = 2°C Fj = 7°C Fj = 12°C Fj = bivalent temperature Fj = operating limit temperature Fj = -15°C Bivalent temperature Heating (Average) Heating (Warmer)	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv Tbiv	2.33 at indoor temp	kW coerature 20 kW kW kW kW kW kW coerature 20 co	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	at indoor	
Fj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fj = 7°C Fj = 2°C Fj = 7°C Fj = 12°C Fj = bivalent temperature Fj = operating limit temperature Fj = -15°C Bivalent temperature Heating (Average) Heating (Warmer)	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv	2.33 at indoor temp	kW kW kW kW kW kW kW kW kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	at indoor	
Power consumption of cycling Poeclared capacity (*) for heating / C and outdoor temperature Tj Pi = -7°C Pi = 2°C Pi = 2°C Pi = 12°C Pi = bivalent temperature Pi = operating limit temperature Pi = -15°C Bivalent temperature Pleating (Average) Heating (Colder) Power consumption of cycling	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv Tbiv Tbiv	2.33 at indoor temp	kW kW kW kW kW kW kW contained to the contained to	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling	COPd ce (*) for heating / inperature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	at indoor	
Fig = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Fig = 7°C Fig = 2°C Fig = 2°C Fig = 12°C Fig = bivalent temperature Fig = operating limit temperature Fig = -15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv Tbiv Tbiv Tbiv Tbiv Tbiv	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = bivalent temperature Tj = operating limit temperature Tj = operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Fj = operating limit temperature Ceclared capacity (*) for heating / C and outdoor temperature Tj Fj = -7°C Fj = 2°C Fj = 2°C Fj = 12°C Fj = bivalent temperature Fj = operating limit temperature Fj = -15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv Tbiv Tbiv	2.33 at indoor temp	kW kW kW kW kW kW kW contained to the contained to	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling	COPd ce (*) for heating / inperature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Tj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv Tbiv Tbiv Tbiv Tbiv Tbiv	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = bivalent temperature Tj = operating limit temperature Tj = operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Cooling Heating Cooling	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Tbiv Tbiv Tbiv Tbiv Tbiv Colder season,	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 12°C Tj = 12°C Tj = operating limit temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	at indoor	
Declared capacity (*) for heating / C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = 12°C Tj = 12°C Tj = 15°C Tj = 15°C Sivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Degradation coefficient cooling(**) Degradation coefficient cooling(**)	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Declared capacity (*) for heating / C and outdoor temperature Tj	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
j = operating limit temperature C and outdoor temperature Tj j = -7°C j = 2°C j = 7°C j = 12°C j = 12°C j = bivalent temperature j = operating limit temperature j = operating limit temperature j = operating limit temperature deating (Average) deating (Warmer) deating (Colder) Cooling deating Degradation coefficient cooling(**) Electric power input in power mo Off mode Standby mode	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Coclared capacity (*) for heating (C and outdoor temperature Tj (*) = -7°C Tj = 2°C Tj = 2°C Tj = 7°C Tj = 12°C Tj =	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW berature 20 kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C) Heating (Warmer)(+2°C)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Cooling Heating (Warmer) Heating (Colling Heating He	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 12°C Tj = 12°C Tj = operating limit temperature Tj = operating limit temperature Tj = operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C) Heating (Warmer)(+2°C) Heating (Colder)(-22°C)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Colling Heating (Colder) Cololing Heating Hea	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW berature 20 kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 2°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C) Heating (Warmer)(+2°C) Heating (Colder)(-22°C) Other items	COPd Ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Cand outdoor temperature Cand outdoor temperature Cand outdoor temperature Tj Cand outdoor temperature Cand o	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW berature 20 kW	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 2°C Tj = 12°C Tj = 12°C Tj = operating limit temperature Tj = operating limit temperature Tj = operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C) Heating (Warmer)(+2°C) Heating (Colder)(-22°C) Other items Sound power level (indoor/outdoor)	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Poeclared capacity (*) for heating / C and outdoor temperature Tj Fi = -7°C Fi = 2°C Fi = 2°C Fi = 12°C Fi = 12°C Fi = operating limit temperature Fi = operating limit temperature Fi = operating limit temperature Fi = -15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating Degradation coefficient cooling(**) Electric power input in power mo Off mode Standby mode Thermostat-off mode Crankcase heater mode Capacity control type Fixed Staged	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW k	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 2°C Tj = 12°C Tj = 12°C Operating limit temperature Tj = -15°C Operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C) Heating (Warmer)(+2°C) Heating (Colder)(-22°C) Other items Sound power level (indoor/outdoor) Refrigerant type	COPd ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	
Tj = bivalent temperature Tj = operating limit temperature Declared capacity (*) for heating / C and outdoor temperature Tj Tj = -7°C Tj = 2°C Tj = 7°C Tj = 12°C Tj = bivalent temperature Tj = operating limit temperature Tj = -15°C Bivalent temperature Heating (Average) Heating (Warmer) Heating (Colder) Power consumption of cycling Cooling Heating Degradation coefficient cooling(**) Electric power input in power mo Off mode Standby mode Thermostat-off mode Crankcase heater mode Capacity control type Fixed Staged Variable	Pdh / Colder season, Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pdh Pd	2.33 at indoor temp	kW k	Tj = operating limit temperature Declared Coefficient of Performan temperature 20°C and outdoor ten Tj = -7°C Tj = 2°C Tj = 2°C Tj = 12°C Tj = 12°C Tj = operating limit temperature Tj = operating limit temperature Tj = operating limit temperature Heating (Average) Heating (Warmer) Heating (Colder) Efficiency of cycling Cooling Heating Degradation coefficient heating(**) Seasonal electricity consumption Cooling Heating (Average)(-10°C) Heating (Warmer)(+2°C) Heating (Colder)(-22°C) Other items Sound power level (indoor/outdoor)	COPd Ce (*) for heating / herature Tj COPd COPd COPd COPd COPd COPd COPd COP	2.79 Colder season,	- at indoor	

⁽⁵⁾ For multisplit appliances, data shall be provided at a Capacity ratio of 1.

www.argoclima.com

^(**) If default Cd= 0,25 is chosen, then results from cycling tests are not required. Otherwise either the heating or cooling cycling test value is required



Product Fiche

Model: HI-COMFORT PLUS 9000 UE / HI-COMFORT PLUS 9000 UI

Manufacturer: ARGOCLIMA SPA - via Alfeno Varo, 35 - Alfianello (BS) - Italy;

Sound power level (indoor unit / outdoor unit): 53 / 61 dB(A);

Refrigerant: R32

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling mode

SEER: 6, 1

Energy efficiency class: A++

Pdesignc: 2,6 kW

Annual electricity consumption 149 kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

Heating mode

Climate type: Average (-10°C) / Warmer (+2°C) / Colder (-22°C)

SCOP: 4,0/5,1/-

Energy efficiency class: A+/A+++/-

Pdesignh: 2,1/2,3/- kW

The back up heating capacity for SCOP calculation: # kW.

Annual electricity consumption **722/618/-** kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.